

## ELECTRICAL CONDITIONS – Adelaide Showground.

1. No person other than the Adelaide Showground Electrical Department staff will be permitted to carry out electrical work on installations to be connected to the Mains.
2. One fitting only is permitted on any one lighting plug.
3. One fitting only is permitted on any one power point.
4. **Double adaptors are expressly prohibited.**
5. **Power boards (with overload protection and have been test and tagged) may be approved for use by the Electrical Coordinator on application. This will be granted only if fitted with overload protection and appropriately tested and tagged.**
6. All installations and current applied for will be charged, whether used or not.
7. Where an exhibitor brings in to the Adelaide Showground a pre-wired exhibit or stand, a connection, current used and service fee for the period of the event will be determined by the Adelaide Showground Electrical Coordinator appropriate to the electrical installation.
8. Where an exhibitor provides their own fitting/s the installation charges will be the same as if the Adelaide Showground had provided the fitting/s and therefore as set out on the Adelaide Showground scale of charges.
9. Where an exhibitor provides their own lighting and plugs it into an installed power point, the Adelaide Showground reserves the right to charge the appropriate Power Feed cost in place of the power point cost.
10. Where an exhibitor provides their own fitting/s, any necessary service carried out on such fitting/s to make them safe and serviceable, will be in the form of labour only and will not include the provision by the Adelaide Showground of materials or replacement parts. Such labour will be charged on an hourly basis with a minimum charge of 1 hour, and if relevant, penalty rates applying.
11. All exhibitors requiring electrical installations must have their stand/s completed in sufficient time to allow for the wiring of the stand/s prior to the opening of the event. Failure to comply with this condition will result in penalty rates applying and no guarantee is given that such installations will be completed in time for the opening of the event.
12. All electrical fittings and materials supplied remain the property of the Adelaide Showground.
13. As required by Occupational Health and Safety regulations:
  - Where an exhibitor uses a hand held appliance on their stand, whether double insulated or not, the circuit to the appliance must incorporate an approved Earth Leakage Core Balanced device; such device to be provided by the exhibitor.
  - All electrical is required to be safety tested and tagged, to comply with Australian Standard 3760-2003.
14. At the discretion of the Electrical Coordinator and in addition to any other charges applicable, heavy users of current will be charged for current consumed. Current consumed will be calculated either by meter (installed at stand holder's expense), or by the total wattage of the installation.